

Kumar Pure Water Solution (P) Ltd.

109/1, Sec-15-B, Awas Vikas colony, Near Karkunj,
Sikandra, Agra

Email : kpwsagra@gmail.com

Ph / Fax : 0562-2605359 • Mobile : 9837032425



Test Report of R.O. Water

KP-2025/534

Issue to:-

The Principal

Darshan Academy

Delhi

Date of Received Sample :-

23.04.26

Date of Analysis :-

25.04.26

Volume of Sample :-

1 Litre


Sealed/Unsealed :-

Unsealed

Chemical & Microbiological Testing Parameters as Per (IS-14543-2005)

S. No.	Requirement tested	Results	Specification
1.	Colour	Colourless	Colourless
2.	Odour	Agreeable	Agreeable
3.	Taste	Agreeable	Agreeable
4.	Description Appearance	Satisfactory	Satisfactory
5.	Total Dissolved Solids (TDS)	115 mg/litre	500 mg/litre
6.	pH	6.51	5.50 to 8.0
7.	Turbidity	Less Than 1.13 NTU	3 NTU
8.	Chloride	20.04 mg/litre	Max. 200 mg/litre
9.	Sulphate	1.32 mg/litre	Max. 200 mg/litre
10.	Residual Free Chlorine	Not Detected	0.1 mg/litre
11.	Iron (Fe)	Not Detected	0.1 mg/litre
12.	Fluoride	Not Detected	1 mg/litre
13.	Mineral Oil	Not Detected	Not Detected
14.	Calcium	6.57 mg/litre	Max. 75 mg/litre
15.	Magnesium	4.36 mg/litre	Max. 30 mg/litre
16.	E Coli/ 250ml	Absent	Absent
17.	Coliform/250ml	Absent	Absent
18.	Sulphite Reducing anaerobes	Absent	Absent
19.	Pseudomonas Aeruginosa/ 250 ml	Absent	Absent
20.	Aerobic Microbial Count at (20° -22°C ml)	<1/ml	Not exceed 100/ml after 72 hours
21.	Aerobic Microbial Count at (37°C ml)	<1/ml	Not exceed 20/ml in 24 hours
22.	Yeast & Mould/250ml	Absent	Absent

Authorized Signatory



HEAD OF THE SCHOOL
DARSHAN ACADEMY
KIRPAL BAGH
DELHI-110009

MANAGER
Darshan Academy
Kirpal Bagh
Sant Kirpal Singh Marg
DELHI-110009



Deals in : Reverse Osmosis Industrial Plants, Tea / Coffee /
Soup Vending Machine / Premix Tea / Coffee / Soup /
Water Dispenser & Water Cooler